



SECTION 11 61 23 STAGING CONCEPTS SEATING RISER

PART 1-GENERAL

1.1 SUMMARY

- A. This specification section includes the engineering, fabrication, furnishing, delivery and installation of a new Seating Riser as specified.
- B. The Seating Riser shall consist of a system of interlocking platforms of appropriate construction on a support system to provide the height and configuration as indicated.

1.2 SCOPE OF WORK

- A. Comply with the State, Local and Jurisdictional codes.
- B. Work under this section consists of the fabrication of new equipment and installation of a new Seating Riser. Work shall include the installation of all materials and equipment necessary for the proper operation of the Seating Riser.
- C. Preparation and submission of complete engineered shop drawings for approval.
- D. Submission of required record documents.
- E. Coordination with other affected work, trades and inspections.
- F. Final assembly of components to provide a complete, operable system.

1.3 REFERENCES

- A. Aluminum Association (AA):
 - 1. AA Standard AA-M12C22A41.
 - 2. AA Standard AA-M12C22A42/44.
- B. American Institute of Steel Construction (AISC):
 - 1. AISC Manual of Steel Construction.
- C. American Plywood Association (APA)
 - 1. US. Product Standard PS 1-83
- D. American Society for Testing and Materials (ASTM):
 - 1. ASTM A36: Standard Specification for Structural Steel.
 - 2. ASTM A283: Standard Specification for Low and Intermediate Tensile Strength Carbon Steel Plates.

3. ASTM A307: Standard Specification for Carbon Steel Bolts and Studs, 60,000 psi Tensile Strength.
4. ASTM A325: Standard Specification for High-Strength Bolts for Structural Steel Joints.
5. ASTM A500: Standard Specification for Cold-Formed Welded and Seamless Carbon Steel Structural Tubing in Rounds and Shapes.
6. ASTM A501: Standard Specifications for Hot-Formed Welded and Seamless Carbon Steel Structural Tubing.
7. ASTM A570: Standard Specification for Steel, Sheet and Strip, Carbon, Hot-Rolled, Structural Quality.
8. ASTM B209: Standard Specification for Aluminum-Alloy Sheet and Plate.

E. American Welding Society (AWS):

1. AWS D1.1 Structural Welding Code-Steel.
2. AWS D1.3 Structural Welding Code-Sheet Steel, Second Edition.

F. Americans with Disabilities Act (ADA)

G. National Fire Protection Association (NFPA):

1. NFPA 102: Standard for Assembly Seating, Tents, and Membrane Structures.

H. Steel Structures Painting Council (SSPC):

1. SSPC SP3: Power Tool Cleaning.

1.4 RELATED SECTIONS

- A. Section 05 51 00 Metal Stairs
- B. Section 05 52 00 Metal Railings
- C. Section 09 60 00 Flooring
- D. Section 09 90 00 Painting and Coating
- E. Section 12 62 00 Portable Audience Seating

1.5 SUBMITTALS

- A. Comply with Section 01 33 00 Submittal Procedures, unless otherwise indicated.
- B. Product Data: Staging Concepts specifications and technical data including the following:
 1. Detailed specification of construction and fabrication.
 2. Staging Concepts installation instructions.
 3. Certified engineer's reports indicating compliance with performance requirements specified herein.
 4. Description of operations, including step by step set-up and take-down tasks.
- C. Shop Drawings: Prepared by Staging Concepts. Include dimensioned plans, sections and elevations showing Seating Riser component sizes, arrangements and details of each condition of installation. Show fabrication and installation details for each platform type, understructure and accessories.
- D. Samples: Provide samples by request of the owner, architect or consultant.

E. Contract Closeout Submittals: Comply with Section 01 70 00 Execution and Closeout Requirements.

1. Project record documents
2. Operating and maintenance manuals.

1.6 QUALITY ASSURANCE

A. Manufacturer's Qualifications: Not less than 10 years experience in the actual production of portable riser platform units.

B. Installer's Qualifications: Firm experienced in installation or application of systems similar in complexity to those required for this Project.

1. Acceptable to or licensed by manufacturer.
2. Not less than 3 years experience with systems.

C. Welding and Connections:

Welds: Performed by welders certified for the process employed.

1.7 DELIVERY, STORAGE AND HANDLING

A. Packing and Shipping: Deliver products in original unopened packaging as applicable, with legible manufacturer's identification.

B. Storage and Protection: Comply with manufacturer's recommendations.

1. Store in a cool, dry place out of direct sunlight.
2. Protect from the elements and from damage.

1.8 WARRANTY

A. Special Warranty: Staging Concepts written warranty indicating Staging Concepts intent to repair or replace the seating riser platform components that fail in materials or workmanship within three (3) years from the date of substantial completion. Paint and exterior surfaces are excluded. Failures are defined to include, but are not limited to the following:

1. Mechanical defects
2. Damaged materials due to fabrication
3. Material deterioration and discoloration other than normal wear and weathering conditions
4. failure to maintain dimensional stability

PART 2- PRODUCTS

2.1 MANUFACTURER

A. Basis of design: SC90, SC97, SC100, SC2000 and SC9600 based on the design by Staging Concepts.

1. Staging Concepts. 8400 Wyoming Ave. North, Suite 100, Minneapolis, MN 55445
Phone: 763-533-2094. www.stagingconcepts.com

2.2 COMPONENTS

A. SC90 Platform:

Single side, indoor/outdoor, weather resistant, portable platform. Design platform to be fully field repairable and to function with Staging Concepts supports and to comply with the following:

1. Edging: 4 inch [101 millimeter] high extruded 6105-T5 aluminum frame (including protective edge), mill finish (standard), powder coat and anodizing as an option. Design frame to accept:
 - a. Built-in Roto-Lock® system.
 - b. Skirting clip.
 - c. Guardrail.
 - d. Closure panels.
 - e. Chair stops.
 - f. Step units.
 - g. ADA compliant ramps.
2. Subfloor: 1 inch [25 millimeter] thick, Structural 1 (S1) marine grade plywood.
 - a. Finished surface: Polypropylene (black or grey vinyl), carpet, Plyron, acrylic, natural wood, painted wood, or tongue & groove wood.
 - b. Aluminum skin backer
3. Deck will support a uniform live load of 125 psf [610 kg/sq. meter]. Lateral sway-bracing loads: 24 lbs/ft (350 N/m) applied parallel to and 10 lbf/ft. (145.9 N/m) applied perpendicular to platforms. (standard). Additional support beams can be installed to increase load rating.

B. SC97 Platform:

Single side, all aluminum, weather resistant, portable platform. Design platform to be fully field repairable to function with Staging Concepts supports and to comply with the following:

1. Edging: 4-3/4 inch (120 millimeter) high extruded 6105-T5 aluminum frame, mill finish. (standard), anodizing as an option. Design frame to enclose floor and aisle steps and to accept:
 - a. Built-in Roto-Lock® system.
 - b. Latch receptacle to receive engaging latch.
 - c. Skirting.
 - d. Guardrail.
 - e. Chair stops.
 - f. Closure panels.
 - g. Step units.
 - h. ADA compliant ramps.
2. Floor and Aisle steps: Non-slip, ribbed extruded aluminum with surface material thickness of not less than 0.090 inch [2 millimeter]. Provide inverted "T's" at floor underside at approximately 3 inches (76 millimeter) on center. Design material thickness to meet design requirements.
 - a. Through-bolt floor to frame cantilevers using self-tapping screws.
3. Deck will support live load of 125 psf [610 kg/sq. meter]. (standard). Additional support beams can be installed to increase load rating.

C. SC90 Leg Supports:

1. General: For use with SC90 and SC97 decks. Design support system to the following:
2. Legs: 1-1/4 inch [31 millimeter] Schedule 40, 6105-T5 aluminum pipe. Join leg to platform in a compression loading condition. Hold in place by a 3/8 inch [9 millimeter], 16 socket head cap screw with plastic tightening knob.
 - a. Fixed heights: 4 inches to 96 inches (101 millimeters to 2438 millimeters)(Standard) (stabilizer bracing required when at height of 30" [762 millimeters] and over). Custom heights available upon request.
 - b. Adjustable heights: 8 inches to 12 inches [203 millimeters to 304 millimeters], 12 inches to 16 [304 millimeters to 406 millimeters], 16 inches to 24 inches [406 millimeters to 609 millimeters], 24 inches to 36 inches [609 millimeters to 914 millimeters] (stabilizer bracing required), 36 inches to 48 inches [914 millimeters to 1219 millimeters] (stabilizer bracing required).
 - c. Terminate each leg with a non-marring leveling foot to allow for a 2 inch [50 millimeter] fine height adjustment. Fabricate foot from molded skid resistant PVC pad. Optional: Terminate each leg with a nickel-plated foot.
 - d. Capable of being erected without use of tools.
 - e. Finish: Mill (standard), powder coat and anodizing as an option
3. Stabilizer-bracing (when required): 1-1/4 inch [31 millimeter] Schedule 40 6105-T5 aluminum pipe. Connect to leg supports with slip-on structural fitting.

D. SC9600 Bridge Support System:

1. General: For use with SC90 and SC97 decks. Design support system to permit bridging of platforms between units, and to meet the following:
 - a. Fixed heights: 8 inches (203 millimeters) increments starting at 24 inches (609 millimeters).
 - a. Adjustable heights: 18 inches to 24 inches [457 millimeters to 609 millimeters], 24 inches to 36 inches [609 millimeters to 914 millimeters], 32 inches to 54 inches [812 millimeters to 1219 millimeters], 36 inches to 54 inches [914 millimeters to 1371 millimeters], and 48 inches to 76 inches [1219 millimeters to 1930 millimeters]. Custom heights available upon request.
 - b. Adjust course height by 4 inch (101 millimeter) increments using a 5/8 inch [15 millimeter] locking pin. Allow 3 inch [76 millimeter] additional fine height adjustment through use of integral ACME thread adjustable screw foot. Mount screw foot to bottom of main vertical member.
 - c. Capable of being erected without use of tools.
 - d. Finish: Mill (standard), powder coat and anodizing as an option.
2. Main vertical members: 2-1/2 inch [63 millimeter] IPS, Schedule 40, 6105-T5 aluminum pipe.
3. Main horizontal members: 2 inch [50 millimeter] OD by 1/8 inch [3 millimeter] wall, 6105-T5 aluminum tubing.
4. Telescoping columns: 2 inch [50 millimeter] IPS Schedule 80, 6105-T5 aluminum pipe. SC9600AT utilizes inner sleeve that telescopes from the bottom for use on uneven terrain.
5. Cross-bracing: 2 inch [50 millimeter] OD by 1/8 inch [3 millimeter] wall, 6105-T5 aluminum tubing.
 - a. Weld manually operated quick release structural fitting to each end.

E. Relia Beam Spanning Support System:

1. General: For use with SC90 and SC97 decks. Compatible with SC9600 Bridge Support System. Used for improved access below decks and larger opening spans. Design support system to meet the following:
 2. Main support beams: Extruded 6061-T6 aluminum bridging beams with adjustable node plates for panel to beam connection and adjustable top plates for column to beam connections. Connection plates attach using threaded inserts and 3/8" (9.5mm) diameter threaded locking device requiring no tools.
 - a. 16' (4.8m) maximum span unsupported intermediately.
 3. Cross beams: Extruded 6061-T6 aluminum with single fastener track for bracing and column connections, attached to main support columns with pin and socket connection requiring no tools.
 4. Column Assemblies: Extruded 6061-T6 aluminum, with pinned connection to main support beam top plate and threaded leveling foot allowing total adjustment of four inches (100 millimeter), plus or minus.
 - a. Fixed Heights: Can accommodate any requirement.
 - b. Adjustable Heights: Can accommodate any requirement.
 5. Bracing: Extruded 6061-T6 aluminum knee and cross braces. Braces attach to main support and cross beams with pinned connections to columns requiring no tools.
 6. Adjustable Locator Nodes: Attach using 3/8" (10 millimeter) washer and Nylock.

F. SC100 Folding Frame System:

1. General: For use with SC90 and SC97 decks. Design support system to permit bridging platforms between units using DOM or ERW steel tubing, and to meet the following:
 - a. Fixed Heights: 18 inches (457 millimeters), 24 inches (609 millimeters), 32 inches (812 millimeters), 36 inches (914 millimeters), 42 inches (1066 millimeters), 48 inches (1219 millimeters).
 - b. Adjustable heights: 16 inches to 22 inches [406 millimeters to 558 millimeters], 18 inches to 24 inches [457 millimeters to 609 millimeters], 24 inches to 32 inches [609 millimeters to 812 millimeters], 24 inches to 36 inches (609 millimeters to 914 millimeters), 32 inches to 42 inches [812 millimeters to 1066 millimeters], and 36 inches to 48 inches [914 millimeters to 1219 millimeters]. Custom heights available upon request.
 - c. Adjust course height by 2 inch [50 millimeter] increments using a 3/8 inch [9 millimeter] locking pin. Allow additional 2 inch [50 millimeter] fine height adjustment through use of integral ACME thread adjustable screw foot. Mount screw foot to bottom of main vertical member. Bottom of foot shall be non-marring plastic.
 - d. Capable of being erected without use of tools.
 - e. Design frame to allow for bridging effect between platforms.
2. Main vertical members: 2 inch [50 millimeter] OD by 12 gauge steel tube.
3. Telescoping columns: 1 3/4 inch [44 millimeter] OD by 12 gauge steel tube.
4. Cross-bracing: 1 inch by 2 inch [25 millimeter by 50 millimeter] by 14 gauge steel tube.
5. Finish: Mill (standard), powder coat and anodizing as an option.

G. SC2000 Folding Seat Multi-Level Riser System:

1. General: For use with SC90 and SC97 decks. Design support system to permit bridging of decks between units, and to meet the following:
 - a. 3 inch [76 millimeter] fine height adjustment through use of integral ACME thread adjustable screw foot. Mount screw foot to bottom of main vertical member.

- b. Capable of being erected by 2 people without use of tools, and of being folded into 15 percent of overall length.
 - 2. Finish: Mill, powder coat (standard) and anodizing as an option.
 - 3. Main vertical members: Carbon steel round mechanical tubing, ASTM A513 Type 2 (CR).
 - 4. Main horizontal members: Carbon steel square tubing, ASTM A500B.
 - 5. Cross bracing: Low carbon HR flat bar, ASTM A36.
 - 6. Main pivot connection: Aluminum casting, 380 aluminum alloy, 3/8 inch [10 millimeter] grade 5 pivot pins.
 - 7. Casters: Design casters to meet the following:
 - a. To attach to base of system to ease the extension, closure and transport of the system.
 - b. To engage and disengage using a lever handle attached to the system.
 - c. Disengaging the casters will allow full support of seating riser on main vertical columns.
 - d. Maximum lever handle force requirements shall meet OSHA. regulations limiting this force to 60 pounds [27.2 kilograms] applied at the end of the lever arm.
- H. SC CHORAL RISER 6 inches x 18 inches(1.8m x .045m) 3-Tier):
- 1. General: Design system as a mobile, foldable unit with casters to meet the following:
 - a. Performance Dimensions: 72 inches W x 62 inches D x 66 inches H. (1829 millimeters W x 1575 millimeters D x 1677 millimeters H)
 - b. Storage Dimensions: 72 inches W x 25 inches D x 66 inches H. (1829 millimeters W x 635 millimeters D x 1677 millimeters H)
 - c. Weight: 175 lbs (80 kg)
 - d. Lift assist for folding and unfolding. Two gas shock springs.
 - e. Operable by one person for folding, unfolding and rolling.
 - 2. Finish: Black powder coat. (standard)
 - 3. Lightweight aluminum tube.
 - 4. Tread Substrate: 1 inch (25 millimeter) Structural 1 (S1) exterior grade plywood.
 - 5. Tread Surface: Carpet, polyvinyl, unfinished plywood, painted hardboard.
 - 6. Casters: Four heavy-duty 4 inch (102 millimeter) diameter non-locking casters. Two swivel, two rigid. Load rating 700 lbs. (317.5 kilograms).
- I. ADA Compliant Ramps:
- 1. General: Ramp constructed of SC90 or SC97 decks; SC90 Legs, SC100 Folding Frame or SC9600 Supports; Guardrails when required by code; and Aluminum Transition Plate. See drawings for locations and design.

2.3 ACCESSORIES

- A. Design accessories to attach without the use of tools and shall be easily removable.
 - 1. Exposed Fasteners: Non-corrosive and tamper resistant.
- B. Fixed Stair Units:
 - 1. Material: 6061 aluminum pipe. Weld joints together and grind smooth.
 - 2. Finish: Mill, anodized or powder coat.
 - 3. Equip stair system with locking mechanism to allow for attachment to side of platform extrusion.
 - 4. Treads: 12 inches (304 millimeters) deep by 36 inches (914 millimeters) wide or 48 inches (1219 millimeters) wide, unless otherwise specified. Rise not to exceed 7 inches. (177 millimeters)
 - 5. Tread Surface: Match deck surface.
- B. Adjustable Stair Units:
 - 1. Material: 6061-T6 aluminum angle.
 - 2. Finish: Mill, anodized or powder coat.
 - 3. Equip stair system with locking mechanism to allow for attachment to side of deck.

4. Treads: 12 inches (304 millimeters) deep by 36 inches (914 millimeters) wide, unless otherwise specified. Adjustable rises from 16 inches (406 millimeters) to 24 inches (609 millimeters), 24 inches (609 millimeters) to 36 inches (914 millimeters), 30 inches (762 millimeters) to 40 inches (1016 millimeters), 36 inches (914 millimeters) to 48 inches (1219 millimeters), 36 inches (914 millimeters) to 56 inches (1422 millimeters), and 48 inches (1219 millimeters) to 72 inches (1828 millimeters).
5. Tread Surface: Match deck surface.

C. Guardrails:

1. Material: 1 ¼" inch (31 millimeters) Schedule 40 6105-T6 aluminum extrusion.
2. Finish: Mill, Anodized or Powder Coat finish.
3. Toeboard: 4 inch (101 millimeters) extruded aluminum toeboard where required by code.
4. Equip guardrail with locking mechanism to allow for attachment to deck. Design lock mechanism to allow for easy removal.
5. Provide manufacturer's standard guardrails.
 - a. IBC compliant guardrail: Space vertical members so that no sphere 4 inches (101 millimeters) in diameter or larger may pass through.

D. Closure Panels: Provide closure panels meeting the following requirements as directed by design:

1. Material: Plywood substrate construction. Provide polyethylene tee-moulding at top.
2. Finish: Match deck surface.
3. Attach closure panels with snap-on clips ("button-lock" brackets) or set screw to platform frame.

E. Skirting:

1. Material: Flame retardant Wyndham fabric.
2. Thread Color: Match fabric.
3. Pleat skirts with 50 percent fullness.
4. Style: Shirred or box pleat.
5. Reinforce top hem with continuous webbing.
6. Attachment: Attach to platforms with velcro and extruded plastic clips.

F. Aisle Lights:

1. Lights: UL approved.
 - a. Transformer and Wiring: Install hidden below platforms.
 - b. Bulb color: Clear.
2. Fully enclose UL approved lighting in mill finish aluminum aisle strip that attaches to top of closure panel or step unit. Design aluminum aisle strip to cast light downward to highlight stair tread in front of it.
 - a. Incandescent
 - b. LED
3. ECO-GLO light strip: Requires no power source.

G. Chair Stops:

1. Material: 2 inch by 1 inch by 1/8 inch (50 millimeter by 25 millimeter by 3 millimeter) tube, 6015-T5 aluminum extrusion.
2. Finish: Mill or powder coat
3. Attach chair stops to platform along outer edge of platform frame.

H. Transport Carts:

1. leg and bracing cart
 - a. Material: Tubular steel with welded joints. Grind weld joints smooth.
 - b. Casters: Provide 4 casters for each cart; 2 fixed and 2 swivel.
 - c. Caster Sizes: 4 inch or 6 inch (102 millimeter or 152 millimeter) diameter, with a load capacity of 900 pounds (408kg) each.
 - d. Provide pivoting ramp to lock into position with hitch pins.
 - e. Provide pivoting cross members to lock in position with hitch pins.
 - f. Provide straps to hold leg supports during transport.
 - g. Design transport carts to contain intended load in a secure and organized manner.
2. platform cart
 - a. Material: Tubular steel with welded joints. Grind weld joints smooth.
 - b. Casters: Provide 4 casters for each cart; 2 fixed and 2 swivel.
 - c. Caster Sizes: 4 inch or 6 inch (102 millimeter or 152 millimeter) diameter, with a load capacity of 900 pounds (408kg) each.
 - d. Design transport carts to contain intended load in a secure and organized manner.

2.4 FINISHES

A. Aluminum Framing: Mill Finish (standard). Powder coat or anodizing as an option.

B. Platform finish as determined by the architect or owner.

PART 3- EXECUTION

3.1 EXAMINATION

A. Verification of Conditions: Examine areas and conditions under which work is to be performed and identify conditions detrimental to proper or timely completion.

1. Do not proceed until unsatisfactory conditions have been corrected.
2. Field verify dimensions for all units prior to fabrication if indicated by the owner, architect or consultant.

3.2 INSTALLATION

A. Comply with manufacturer's recommendations.

B. Set up each type of removable, collapsible platform and adjust for proper operation and correct assembly.

1. Install plumb and level.
2. Accurately fit, properly align, securely fasten, and install free from distortion or defects.

3.3 CLEANING

A. Clean exposed surfaces of seating riser. Comply with Staging Concepts written instructions for cleaning and touchup of minor finish damage.

B. Repair or replace defective work as directed by the owner, architect or consultant upon inspection.

3.4 TRAINING AND DEMONSTRATION

A. Train Owner's personnel to assemble, adjust, operate and maintain Seating Riser.

END OF SECTION 11 61 23